

Project Name	Blackmer Pump			Job #	ST170026B	Test Date	4/20/17		
Location	70 84th ST. Byron Center MI 49315			Tested By	Lew				
<b>Field Data</b>									
Equipment Location	Outdoor Utilities Building - Off customer site			Transformer ID	522-06				
Manufacturer	Balteau			Serial Number	PTI-0786				
Class	ON	Phase	3	Configuration	Y-Δ		Type	Core	
KVA	1700			Impedence	5.70%	Tap AF	C	Tap AL	Core
Primary Voltage	L-L	12470	L-G	7200	Secondary Voltage	L-L	575	L-G	NA
Winding Material	Primary	NA	Secondary	NA	Temp. Rise	65	Oil Type	Mineral	
				Temperature/Humidity	NA				
<b>Inspection Data</b>									
Visual Inspection	As Found		As Left		Visual Inspection	As Found		As Left	
Physical/Mechanical	A		A		Level Gauge	A		A	
Enclosure Condition	N		C		Pressure Gauge	A		A	
Barriers/Insulators	A		A		Liquid Temp. Gauge	A		A	
Cooling Fins	A		A		Winding Temp. Gauge	NA		NA	
Grounding	NA		NA		Cooling Fin Condition	A		A	
Anchorage	NA		NA		Fans	NA		NA	
Cleanliness	A		A		Bushings	A		A	
Connection Tightness	NA		NA		Pressure Relief	A		A	
Legend: A-Acceptable N-Needs Correction C-Corrected NA-Not Applicable NS-Not In Scope									