



VESSEL (A): 2763802  
DATE OF INSPECTION: 1998 Aug 25



# Certificate of Inspection

**NUMAC ENERGY INC.**

ATTN: JEFF WICKENS  
321 - 6 AVENUE SW  
CALGARY, AB  
T2P 3H3

LOCATION: PINE CREEK, LSD 7-28-57-19-W5M

COMPANY CODE: V-100

PREFERRED RE-INSPI. INTERVAL: 4.00 Yr.

DESCRIPTION: SEPARATOR

CRN: K9026.2

MANUFACTURER: PRESSON MANUFACTURING LTD.

SERIAL #: 5236-20

YEAR BUILT: 1993

HEATING SURFACE:

SURFACE AREA:

VOLUME: 2.04 M3

**Safety Valves**

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
SEP	4964 KPA	37 C	-29 C	SV1	4306 KPA	283 M3/MIN	VESSEL

**OWNER INSTRUCTIONS/REMARKS:**

REQUIRES ULTRASONIC THICKNESS SURVEY TO VERIFY FITNESS FOR SERVICE.

**Safety Codes Officer:** DURNFORD, FRED

**Signature:**

**NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:**

owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.