

Performance Specification

Project Name: **454B Stock AC Scrolls YLAA Submittals**

Unit Tag:
YLAA0200HJ46VSD

Qty.: 1

Model: **YLAA0200HJ46XF**

Full Load - Design

PIN

YLAA0200HJ	46XFBBCTXA	SXBLXCXX44	SE1XXXHXXX	YAXGXXX3XX	XVXNXXXXXX			
...5...10	...5...20	...5...30	...5...40	...5...50	...5...60	...5...70	...5...80	...5...90

Unit	
Model No.	YLAA0200HJ46XFB
Number of Compressors	6
Compressor Type	Scroll - Hermetic
Number of Compressor Circuits	2
Refrigerant	R454B
Performance Data	
Cooling Capacity [tons.R]	192.8
Total Power Input [kW]	222.9
EER [Btu/W.h]	10.38
IPLV/IP [Btu/W.h]	18.46
A-Weighted Sound Power [dB(A)]	98.0
Electrical Data	
Nominal Voltage / Voltage Limits	460/3/60 / 414-506
Compressor RLA (each circuit) [A]	51.4 / 51.4 / 51.4 / 51.4 / 51.4 / 51.4
High LRA Current (each circuit) [A]	316.0 / 316.0 / 316.0 / 316.0 / 316.0 / 316.0
Fan QTY (each circuit)	6 / 6
Fan FLA (each circuit) [A]	4.0 / 4.0
Min. Circuit Ampacity [A]	374.0
Recommended Fuse / CB Rating [A]	400.0
Max. Inverse Time CB Rating [A]	400.0
Max. Dual Element Fuse Size [A]	400.0
Unit Short Circuit Withstand [kA]	65 kA
Wires Per Phase	2 + 1
Wire Range (Lug Size)	#3/0 AWG - 250 kcmil + 250 - 500 kcmil
Compressor kW	202.8



Performance Impacting Options

Starter Type	Across the line starter
Power Factor Correction Capacitor	No Power Capacitor required
Remote Evaporator	Standard Cooler required
Sound Kit	No Acoustic Blanket required
Fan	Low Sound Fans with VSD

Weight & Dimensional Data

Shipping Weight [lbs]	9991
Operating Weight [lbs]	10119
Refrigerant Charge [lbs]	160
Length [in]	274.8
Width [in]	88.3
Height [in]	94.2



Performance Report

Page 2 of 4

Performance Specification

Project Name: **454B Stock AC Scrolls YLAA Submittals**

Unit Tag:
YLAA0200HJ46VSD

Qty.: **1**

Model: **YLAA0200HJ46XF**

Heat Exchanger Performance

Evaporator		Condenser (Air Cooled)	
Heat Exchanger Type	Plate Heat Exchanger	Ambient Air Temperature* [°F]	95.0
Entering Fluid Temperature* [°F]	54.00	Altitude* [ft]	0.00
Leaving Fluid Temperature* [°F]	44.00	Condensing Temperature [°F]	120.44 / 120.44
Flow Rate [USGPM]	460.3	Number of Fans	6 / 6
Fouling Factor* [h ft ² F/Btu]	0.000100	Total Air Flow [cfm]	180000
Fluid Type*	Water	Total Fan Power [kW]	20.16
Fluid Volume [USGAL]	12.7		
Evaporating Temperature [°F]	37.35		
Evaporator Pressure Drop [ft H ₂ O]	18.4		
Strainer Pressure Drop [ft H ₂ O]	5.48		
Extension Kit Pressure Drop [ft H ₂ O]	1.48		
Total Pressure Drop [ft H ₂ O]	25.3		
Fluid Connection Diameter [in]	5		
Minimum Flow Rate [USGPM]	230.0		
Maximum Flow Rate [USGPM]	625.0		

* Designates user specified input

Certified in accordance with the AHRI Air-Cooled Water-Chilling Packages Using Vapor Compression Cycle Certification Program, which is based on AHRI Standard 550/590 (I-P) and AHRI Standard 551/591 (SI). Certified units may be found in the AHRI Directory at www.ahridirectory.org.



Part Load Performance (Based on Standard AHRI Unloading)

Percent Load	Ambient [°F]	Capacity [tons.R]	Power Input [kW]	Unit Efficiency [Btu/W.h]
100.0	95.0	192.8	222.9	10.38
75.8	80.0	146.1	117.0	14.98
56.8	80.0	109.4	84.24	15.59
61.7	65.0	118.9	72.95	19.56
41.2	65.0	79.40	45.25	21.06
43.5	55.0	83.83	41.74	24.10
21.0	55.0	40.43	20.25	23.95



Performance Report

Page 3 of 4

Performance Specification

Project Name: **454B Stock AC Scrolls YLAA Submittals**Unit Tag:
YLAA0200HJ46VSDQty.: **1**Model: **YLAA0200HJ46XF**

Sound Power Levels (In Accordance with AHRI 370)

Percent Load	Ambient [°F]	Octave Band Center Frequency [Hz]								LWA
		63	125	250	500	1000	2000	4000	8000	
100.0	95.0	101.0	100.0	96.0	96.0	92.0	90.0	86.0	82.0	98.0
75.8	80.0	94.0	93.0	89.0	90.0	87.0	85.0	81.0	76.0	92.0
56.8	80.0	89.0	88.0	84.0	84.0	82.0	83.0	78.0	72.0	88.0
61.7	65.0	54.0	42.0	64.0	74.0	79.0	82.0	76.0	67.0	85.0
41.2	65.0	52.0	40.0	62.0	72.0	77.0	80.0	74.0	65.0	83.0
43.5	55.0	52.0	40.0	62.0	72.0	77.0	80.0	74.0	65.0	83.0
21.0	55.0	49.0	37.0	59.0	69.0	74.0	77.0	71.0	62.0	80.0

Note: Unit is equipped with Low Sound Fans with VSD.

Measurement of sound pressure used to obtain the sound power data presented is based on AHRI-370.

Air-cooled chillers are rated in terms of sound power not sound pressure. Johnson Controls provides estimates of sound pressure, but this is not the rating metric.

For an air-cooled chiller, sound pressure calculated from sound power varies depending on how the chiller is assumed to behave, i.e. the radiation model. In other words, determining sound pressure from sound power requires making assumptions that result in different answers at a given distance from the chiller. The environment also influences sound pressure in the field installation. Sound pressure estimation radiation models pertaining to air-cooled chillers include the 'traditional' hemispherical model, parallelepiped model and equivalent hemispherical model.

Regarding sound power, Johnson Controls references tolerance limits based on ASHRAE guidelines. These are +/- 6dB in the 63Hz octave band, +/- 4dB in all other octave bands and +/- 3dB for the overall dBA.

Tolerance limits are based on uncertainties associated with:

1. Measurement Test Procedure
2. Repeatability
3. Production / Manufacturing Variability

Standard deviation associated with air-cooled chiller sound data is a measure of spread i.e. it indicates the range of probability of sound levels. Note that for operating conditions other than AHRI's Standard Rating Condition, higher levels of uncertainty can be expected.

Lead times for factory performance testing depend on test laboratory availability. Please confirm with Johnson Controls Customer Service.

Performance at AHRI Conditions

Evaporator		Condenser	
EFT [°F]	54.00	Ambient Temp. [°F]	95.0
LFT [°F]	44.00	Altitude [ft]	0.00
Flow Rate [USGPM]	460.3	Performance	
Pressure Drop [ft H ₂ O]	18.4	EER [Btu/W.h]	10.38
Fluid Type	Water	IPLV.IP [Btu/W.h]	18.46
Fouling Factor [h ft ² F/Btu]	0.000100	Net Cooling Capacity [tons.R]	192.8
Fluid Volume [USGAL]	12.7		

Note: Unit rated at design condition capacity.



Performance Report

Page 4 of 4

Performance Specification

Project Name: **454B Stock AC Scrolls YLAA**
Submittals

Unit Tag:
YLAA0200HJ46VSD

Qty.: **1**

Model: **YLAA0200HJ46XF**

Part Load Performance (Based on AHRI 550/590 - 2018 (IP))

Percent Load	Ambient [°F]	Capacity [tons.R]	Power Input [kW]	Unit Efficiency [Btu/W.h]
100.0	95.0	192.8	222.9	10.38
75.8	80.0	146.1	117.0	14.98
56.8	80.0	109.4	84.24	15.59
61.7	65.0	118.9	72.95	19.56
41.2	65.0	79.40	45.25	21.06
43.5	55.0	83.83	41.74	24.10
21.0	55.0	40.43	20.25	23.95

Notes:

Country of Origin: Mexico

Min flow rate is for chillers using water. For glycol chillers please contact the application engineering team.

This unit does not have a coil coating selected.

Compliant with ASHRAE 90.1 - 2010, 2013, 2016.

Compliant with IECC - 2012, 2015, 2018.

Compliant with the requirements of the LEED Energy and Atmosphere Enhanced Refrigerant Management Credit (EAc4).

The product image shown is for illustrative purposes only and is not representative of selected options.

Equipment Description
Base Unit/Access. (3369)
Base Unit - YLAA0200HJ
R454B Refrigerant (Fully Charged)
Voltage Code - 460/3/60
Across the line starter
SP Circuit Breaker w/ Lockable Handle, 65kA SCWR
Control Transformer Required
Both Low/High Ambient Kit
Connected Services Ready - SC-Equip Board
English
North American Safety Code (cUL/cETL)
Service Isolation Valves
Electronic Expansion Valves
Hot Gas Bypass required - 1 circuit
Extension Kit
Dispersion Switch
ASME Pressure Vessel Codes
Aluminum MCHX Coils
No Heat Recovery
Wire/Louvered Encl Panels (factory)
No Acoustic Blanket required
Low Sound Fans with VSD
Neoprene Isolators
No Pump required



YLAA Air Cooled Scroll Chillers

Page 1 of 1


AVM Report

Project Name: 454B Stock AC Scrolls YLAA
SubmittalsUnit Tag:
YLAA0200HJ46VSD

Qty.: 1

Model No.: YLAA0200HJ46XF

PIN								
YLAA0200HJ	46XFBCTXA	SXBLXCXX44	SE1XXXHXXX	YAXGXXX3XX	XVXNXXXXXX			
....5...10	5...20	5...30	5...40	5...50	5...60	5...70	5...80	5...90








LOCATION	X Distance (in)	Y Distance (in)	JCI PART NUMBER	SAP NUMBER	COLOUR	Operating Weights (lb)
R1	7.7	1.4	029-25335-001	434002	Charcoal	814
R2	76.7	1.4	029-25335-002	434004	Red	1226
R3	149.1	1.4	029-25335-002	434004	Red	1126
R4	212.5	1.4	029-25335-001	434002	Charcoal	419
R5	263.9	1.4	029-25335-001	434002	Charcoal	770
L1	7.7	86.9	029-25335-002	434004	Red	1052
L2	76.7	86.9	029-25335-004	434005	Charcoal	2180
L3	149.1	86.9	029-25335-002	434004	Red	1344
L4	212.5	86.9	029-25335-001	434002	Charcoal	419
L5	263.9	86.9	029-25335-001	434002	Charcoal	769

Total Weight (lb)		Centre of Gravity (in)	
Operating Weights (lb)	10119	Xg [in]	121.4
Shipping Weight [lb]	9992	Yg [in]	50.1

NOTE:


1. PLACEMENT ON A LEVEL SURFACE FREE OF OBSTRUCTIONS (INCLUDING SNOW, FOR WINTER OPERATION) OR AIR-CIRCULATION ENSURES RATE PERFORMANCE, RELIABLE OPERATION AND EASE OF MAINTENANCE. SITE RESTRICTIONS MAY COMPROMISED MINIMUM CLEARANCES INDICATED BELOW, RESULTING IN UNPREDICTABLE AIR FLOW PATTERNS AND POSSIBLE DIMINISHED PERFORMANCE. JOHNSON CONTROLS UNIT CONTROLS WILL OPTIMIZE OPERATION WITHOUT NUISANCE HIGH PRESSURE SAFETY CUTOUT. HOWEVER, THE SYSTEM DESIGNER MUST CONSIDER POTENTIAL PERFORMANCE DEGRADATION.
- 1.1. RECOMMENDED MINIMUM CLEARANCES:
 - 1.1.1. SIDE TO WALL - 1828.8mm [72.00]
 - 1.1.2. REAR TO WALL - 1828.8mm [72.00]
 - 1.1.3. CONTROL PANEL TO WALL - 1219.2mm [48.00]
 - 1.1.4. TOP - NO OBSTRUCTIONS ALLOWED.
 - 1.1.5. DISTANCE BETWEEN ADJACENT UNITS - 3048mm [120.00]
 - 1.1.6. NO MORE THAT ONE ADJACENT WALL MAY BE HIGHER THAN UNIT.
2. WEIGHT AND CENTRE OF GRAVITY- REF TO AVM REPORT
3. INSTALLING CONTRACTOR MUST INCLUDE VENT AND DRAIN ACCOMMODATIONS IN CHILLED WATER PIPING NEAR EVAPORATOR.
4. NUMBER OF COMPRESSORS MAY VARY FROM DRAWING.
 - 4.1. REFER TO YORKWORKS REPORTS
5. FOR MONTERREY, MEXICO AND SAN ANTONIO, TEXAS BUILDS ONLY.



THIS DRAWING PERTAINS TO THE FOLLOWING MODELS:		
YLAA 0200 HE		
YLAA 0230 HE		

REV.	DATE	EC. NO.	DR.	CHK.	ENG.
E	24-AUG-2018	DX18-0330	FJM	FJM	
B13-16; ADDED TABLE, G6; DELETED DIM 2938, C9; ADDED DIM 4030, D1-3 ADDED DIM'S 36, DIM 138 ADDED WATER CONN., 14; DELETED DIM 36.4, B1; DELETED DRAWING TOL BLOCK, J-L 4-10; ADDED DIM'S FOR FAN LOC, B7; DIM 7000 WAS 7006, E-F10; ADDED OPTIONAL HEAT RECOVERY UNIT.					
CONTINUED					

"ALL PROPRIETARY RIGHTS IN THE SUBJECT MATTER HEREOF ARE RESERVED AND NO PERMISSION IS GRANTED TO REPRODUCE THIS PRINT IN WHOLE OR IN ANY PART, OR DISCLOSE ANY OF THE INFORMATION UPON IT TO OTHERS WITHOUT WRITTEN RELEASE BY JOHNSON CONTROLS INCORPORATED"



JOHNSON CONTROLS - BUILDING EFFICIENCY
507 EAST MICHIGAN STREET, MILWAUKEE, WI, 53202 USA

DO NOT SCALE	YLAA 12-FAN 60HZ 0200 & 0230 WITH OPTIONAL HEAT RECOVERY	MATERIAL - ENG. STD. - PART NO. - CUT SIZE N/A
DRAWN M. LUPTON 19-FEB-2016	CAGE NUMBER 66935	DRAWING NUMBER 035-24059-014
MODEL M. LUPTON 19-FEB-2016	REVISION E	VERSION 0
CHKD A. SAYCH 19-FEB-2016		
ENG A. KELLY 19-FEB-2016		
SCALE: 0.050	MASS (kg): 0.000	ORIG. NO.: -
		SHEET 1 OF 1