


DRYER No. 2
NO. 6. PM

FORM 7



Hon. Charles Daley
Minister

No. 60-2018-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PMG / Dyer 1

manufactured by Dominion Engineering Works Limited, Montreal, Quebec.

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3431
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by P. Rivest.
ISSUED at TORONTO the 17th day of March, 1960

INSPECTOR


J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

NO. 6 PM

FORM 7

No. 60-2023-A



Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel.

PM6 / DEYER 2

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3443
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set

at 75 PSI Inspected on 30th January, 19 60, by R. Rivest

PROVINCE OF QUEBEC

ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR


R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER NO.3
NO. 6 P.M.

FORM 7

Hon. Charles Daley
Minister



No. 60-2026-A
J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. P-16/Dryer 3

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3451
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs./ Inspected on 30th January, 19 60, by J.J. Mailloux No.6.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 17th day of March, 19 60
INSPECTOR J. J. Mailloux
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

Hon. Charles Daley
Minister



No. 60-2024-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel Pm6 / dryer 4

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr. HT 3444
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set

at 75 lbs. Inspected on 30th January 19 60, by J.J. Mailoux No.6.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR
J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 5
NO 6 P.M.

FORM 7



Hon. Charles Daley
Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. Plate / Drums

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I..
T.Shell 1-1/8"

Sr.No. HT 3379
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by PROVINCE OF QUEBEC R.Rivest.
ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR

E. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 6
No. 6 P.M.

FORM 7

No. 60-2020-A



Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Prb/days/b

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3436
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by J.O. Allaire No.6.
ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

ORDER NO. 7
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1997-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60"x 182" Unfired Pressure Vessel. PMG/deyer

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No, B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3341
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set

PROVINCE OF QUEBEC

at 75 lbs. Inspected on 30th January, 19 60, by J.E. Banville

INSPECTOR

ISSUED at TORONTO the 15th day of March, 19 60


J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 8

NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2002-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Plate/dryer 8

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF MANUFACTURER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T. Shell 121/8"

Sr. No. HT-3359
Temp. 320°F
T. Heads 2" 2½"
U-1959

(NAME AND ADDRESS OF OWNER)

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 1960, by J.E. Banville.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 15th day of March, 1960


INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER NO. 9
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2009-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel.

PM6/Dryer 9

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3381
Temp. 320°F
T. Heads 2" 2 1/2"
1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by J.O. Allaire No.6.
ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER NO. 10
No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1988-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel PM6 / DRYER 10

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF MANUFACTURER)

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3311
Temp. 320°F
T.Heads 2" 2 1/2"
U 1959


has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by R. Rivest
ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

Hon. Charles Daley
Minister



No. 60-2006-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. Pr 6 / Deyer 11

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3374
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set

PROVINCE OF QUEBEC

R.Rivest

INSPECTOR

at 75 lbs Inspected on 30th January, 19 60, by R. Rivest

ISSUED at TORONTO the 17th day of March, 19 60

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM 6 / DYEL 12

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF MANUFACTURER)
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"
Sr.No. HT 3250
Temp. 320°F
T.Heads 2" 2.1/2"

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by R. Rivest
ISSUED at TORONTO the 15th day of March, 19 60


INSPECTOR
R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

PRTER NO. 13
NO. 6 P.M.

FORM 7

No. 60-1994-A



Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel.

PM6 / DYER 13

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"
Sr.No. HT 3329
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by J.E. Banville.
ISSUED at TORONTO the 15th day of March, 19 60


INSPECTOR

J. Hutchison
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DATE No. 14
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2000-A
J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel PM6 / Dryer 14

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3349
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by R. Rivest
PROVINCE OF QUEBEC

ISSUED at TORONTO the 15th day of March, 19 60
INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 15
No. 6 P.M.

FORM 7

No. 60-2010-4

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Pmb / DRYER 15

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/6"
Sr.No. HT 3389
Temp 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 1960, by J.E. Banville.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 17th day of March, 1960

INSPECTOR

E. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DATE NO. 16
NO. 6 P.M.

FORM 7

No. 60-1983-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel.

Per 6/Dec 16

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF MANUFACTURER)

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3299
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.O. Allaire No.6.
ISSUED at TORONTO the 15th day of March, 1960

INSPECTOR

J. Gutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

FORM 7



Hon. Charles Daley
Minister

No. 60-2001-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM 6 / DECE 17

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"
Sr. No. HT 3356
Temp. 320°F
T.Heads 2" 2 1/2"
1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by J.E. Banville.
ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL


DRYER NO. 18
NO. 6 P.M.

FORM 7

No. 60-1975-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6 / dryer 18

manufactured by Dominion Engineering Works Limited, Montreal, Quebec.

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"
Sr.No. HT 3254
Temp 320°F
T.Heads 2" 2 1/2"
U 1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs Inspected on 30th January 1960, by R. Rivest
PROVINCE OF QUEBEC

ISSUED at TORONTO the 15th day of March 1960

INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL


DRTEL No. 19
NO. 6 P.M.

FORM 7

No. 60-2022-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6/Days 119

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 121/8"

Sr.No. HT 3440
Temp. 320°F
T.Heads 2" 2½"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set

PROVINCE OF QUEBEC

at 75 lbs. Inspected on 30th January, 19 60, by J.J. Mailloux No.6.

INSPECTOR


ISSUED at TORONTO the 17th day of March, 19 60

J. J. Mailloux
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER NO. 20
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1991-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel.

Pm6 / DRYER 20

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T. Shell 1-1/8"

Sr.No. HT 3325
Temp. 320°F
T. Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction and I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.O. Allaire No.6
ISSUED at TORONTO the 15th day of March, 1960


INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DATE No. 21
No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1990-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Page 21

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3315
Temp. 320°F
T. Heads 2" 2 1/2"

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 P.S.I. with safety-valves set
at 75 P.S.I. Inspected on 30th January, 19 60, by J.J. Mailloux No. 6.
ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRTEL NO. 22
NO 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1992-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. PM6/DECE 22

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT-3326
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set

PROVINCE OF QUEBEC

at 75 PSI Inspected on 30th January, 19 60, by R.Rivest.

ISSUED at TORONTO the 15th day of March, 19 60


INSPECTOR

R. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

PRYER NO. 23
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2011-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Rm 6 / Dwyer 23

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)
for Howard Smith Paper Mills, Cornwall, Ontario.
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B08337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"
Sr.No. HT 3401
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 1960, by R. Rivest
ISSUED at TORONTO the 17th day of March, 1960

INSPECTOR
R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

ORDER NO. 24
No. 6 P.M.

FORM 7

No. 60-2005-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. PM6/DEYER 24

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3366
Temp. 320°F
T.Heads 1-1/8"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by R.Rivest.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 25
No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 601993-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. *PM 6/DEYER 25*

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3327
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI *with safety-valves set*
at 75 PSI Inspected on 30th January, 1960, by R. Rivest
ISSUED at TORONTO the 15th day of March, 1960


INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 26
No 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2007-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6/DRYER 26

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3376
T.S. 3200F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set

PROVINCE OF QUEBEC

at 75 PSI Inspected on 30th January, 1960, by J.E. Banville.

ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR

R. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

PRINTED No. 27
NO 6 P.M

FORM 7



Hon. Charles Daley
Minister

No. 60-1979-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Pm6/Dec 27

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)
for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"
Sr.No. HT 3285
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.J. Mailloux No.6
ISSUED at TORONTO the 15th day of March, 1960

INSPECTOR
J.J. Mailloux
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYED NO.28
NO. 6 P.M.

FORM 7

No. 60-1980-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. PM 6 / Dec 28

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)
for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3290
Temp. 320°F
T.Heads 2" 2 1/2"
U-69

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 20th January, 19 60, by PROVINCE OF QUEBEC
ISSUED at TORONTO the 13th day of March, 19 60 H.P. Bonnier.

INSPECTOR
R. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 29

No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1971-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Pm6 / Dryse 29

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 PSI
T.Shell 1-1/8"
Sr.No. HT3246
Tem. 320°F
T.Heads 2" 2 1/2"

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by H.P. Bonnier
ISSUED at TORONTO the 15th day of March. 19 60


INSPECTOR

R. Hutchison
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

PRYER NO. 30
NO. 6 PM

FORM 7



Hon. Charles Daley
Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM 6/Dec 30

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. E-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3305
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.J. Mailloux No. 6
ISSUED at TORONTO the 16th day of March, 19 60


INSPECTOR

J. J. Mailloux
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER NO. 31
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1996-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. Rm6 / Dryer 31

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3331
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.O. Allaire No.6
ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR

J. Gutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 32
No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1974-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Pr 6 / Dec 32

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)
for Howard Smith Paper Mills, Cornwall, Ontario.
(NAME AND ADDRESS OF OWNER)

and identified by the following markings


Quebec No. B-8337-5
Max. W.P. 75 PSI
T.Shell 1-1/8"
Sr.No. HT 3252
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 1960, by J.J. Mailloux No. 6.
ISSUED at TORONTO the 15th day of March, 1960

INSPECTOR
J.J. Mailloux
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

FORM 7



Hon. Charles Daley
Minister

No. 60-1986-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Prb/ Dye 33

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T. Shell 1-1/8"
Sr. No. HT 3308
Temp. 320°F
T. Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction and I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set

at 75 PSI Inspected on 30th January, 1960, by R. Rivest

ISSUED at TORONTO the 15th day of March, 1960

INSPECTOR


R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 34

No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1981-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Pmb/Dryer 34

manufactured by Dominion Engineering Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT-3294
Temp. 320°F
T.Heads 2" 2 1/2"

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs./ Inspected on 30th January, 1960, by J.E. Barville.
ISSUED at TORONTO the 15th day of March, 1960


INSPECTOR

J. Gutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DETER NO. 35
No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1989-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM 16/ DEYER 35

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF MANUFACTURER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3313
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959


has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by R.Rivest.
ISSUED at TORONTO the 15th day of March, 1960

INSPECTOR
R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 36
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1982-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. Prk/Dryer 36

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1.1/8"

Sr.No. HT 3297
Temp. 320°F
T.Heads 2" 2½"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by PROVINCE OF QUEBEC
ISSUED at TORONTO the 15th day of March, 19 60 J.E. Banville.
INSPECTOR

J. Gutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL


No. 60-1984-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH



PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. PM6/ DRYER 37

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"
Sr.No. HT 3302
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by J.E. Banville.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 15th day of March, 19 60


INSPECTOR

J. Gutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DEYER No. 38
NO. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1987-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM 6/DEYER 38

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3310
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 1960, by R. Rivest
ISSUED at TORONTO the 15th day of March, 1960


INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 39
NO 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1978-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel.

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

for Howard Smith Paper Mills, Cornwall, Ontario

and identified by the following markings

Quebec No. B-8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3281
Temp. 320°F
T.Heads 2" 2 1/2"
U 1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by R. Rivest.
ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No 4-0
No 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-1972-A
J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. PM 6/Dec 40

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-833705
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3249
Temp. 320°F
T.Heads 2" 2 1/2"

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by R.Rivest.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR

L. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 41
No. 6 P.M.

FORM 7

No. 60-2003-A



Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel PMG / DRYER 41

manufactured by Dominion Engineering Works Limited, Montreal, Quebec.

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario.

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. 8337.5

Max. W.P. 75 P.S.I.

T.Shell 1-1/8"

Sr.No. HT 3361

Temp. 320°F

T.Heads 2" 2 1/2"

U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set

PROVINCE OF QUEBEC

at 75 lbs. Inspected on 30th January, 1960, by R. Rivest.

ISSUED at TORONTO the day of 19

INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL


DRYER No. 42
NO 6 P.M.

FORM 7

No. 60-2028-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. Prk/Dryse 42

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3457
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by R. Alvest
ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR

R. Hutchison
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER NO. 43

No 6 P.M

FORM 7



Hon. Charles Daley
Minister

No. 60-1976-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. pn 61 de yse 43

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3255
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set

PROVINCE OF QUEBEC

at 75 PSI Inspected on 30th January, 19 60, by H.P. Bonnier.

INSPECTOR

ISSUED at TORONTO the 15th day of March, 19 60

L. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 44
NO 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2021-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. PM6 / Reg 44

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337,5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT-3439
Temp. 320°F
T.Heads 2" 2 1/2"
U 1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by R.Rivest
ISSUED at TORONTO the 17th day of March, 1960

INSPECTOR


R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No 4-5
NO. 6 P.M.

FORM 7

No. 60-2004-A



Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. PM6 / DRYER 45

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3364
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 1960, by J.E. Banville.
ISSUED at TORONTO the 17th day of March. 1960

PROVINCE OF QUEBEC

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 47
No 6 P.M.

Hon. Charles Daley
Minister

DEPARTMENT OF LABOUR

PROVINCE

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure

manufactured by Dominion Engineering Works

for Howard Smith Paper Mills,

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

has been inspected under section 15 of the A

it may be operated or used safely at a maxi

at 75 PSI Inspected on 30th Januar

ISSUED at TORONTO the 17th day of Mar

HANG THIS CERTIFICATE NEA

DRYER No. 46
No. 6 P.M.

Hon. Charles Daley
Minister

DEPARTMENT OF LABOUR

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. 2061-De-46

manufactured by Dominion Engineering Works Limited, Montreal, Quebec.

for Howard Smith Paper Mills, Cornwall, Ontario

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT


it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set

at 75 lbs. Inspected on 30th January, 1960, by R. Rivest

ISSUED at TORONTO the 17th day of March, 1960

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

FORM 7



No. 60-2019-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. 2061-De-46

manufactured by Dominion Engineering Works Limited, Montreal, Quebec.

for Howard Smith Paper Mills, Cornwall, Ontario

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set

at 75 lbs. Inspected on 30th January, 1960, by R. Rivest

ISSUED at TORONTO the 17th day of March, 1960


HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

R. Rivest
INSPECTOR
CHIEF INSPECTOR

DRYER No. 48

No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2029-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6 / DEFE 48

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3461
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 19 60, by J.J. Mailloux No.6.
PROVINCE OF QUEBEC

ISSUED at TORONTO the 17th day of March, 19 60


INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER NO. 49
No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2016-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM 6 / page 49
manufactured by Dom inion Engineering Welding Limited, Montreal, Quebec
for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF MANUFACTURER)
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3427
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.J. Mailloux No.6.
ISSUED at TORONTO the 17th day of March, 1960


INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 50
No. 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2025-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6/DECEMBER 56

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5

Max. W.P. 75 P.S.I.

T.Shell 1-1/8"

Sr.No. HT 3447

Temp. 320°F

T.Heads 2" 2 1/2"

U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set PROVINCE OF QUEBEC

J.J. Mailloux No.6.

INSPECTOR

at 75 lbs. Inspected on 30th January, 19 60, by J.J. Mailloux


ISSUED at TORONTO the 17th day of March, 19 60

CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 51
No. 6 D.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2014-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6 / DRYER 51

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3414
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by J.J. Mailloux No.6.
ISSUED at TORONTO the 17th day of March, 19 60

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

FORM 7



Hon. Charles Daley
Minister

No. 60-2030-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel.

Rm6 / Dryer 52

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

Howard Smith Paper Mills, Cornwall, Ontario

for

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 PSI
T.Shell 1-1/8"

Sr.No. HT 3464
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by J.J. Mailloux No.6
ISSUED at TORONTO the 22nd day of March, 19 60

INSPECTOR


CHIEF INSPECTOR

HAVE THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DETER No. 53
No. 6. P.M.

FORM 7

No. 60-2013-A



Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel.

PM 6 / 24562 S3

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3409
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.O. Allaire No.6.
ISSUED at TORONTO the 17th day of March, 1960

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

ORDER No. 54
No. 6 P.M.

FORM 7

No. 60-2027-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM 6 / DEPR 54

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337 5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3454
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 lbs with safety-valves set
at 75 lbs. Inspected on 30th January, 1960, by J.O. Allaire No.6.
ISSUED at TORONTO the 17th day of March, 1960

INSPECTOR

J. Hutchison
CHIEF INSPECTOR


HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

FORM 7

No. 60-2017-A

Hon. Charles Daley
Minister

J. B. Metzler
Deputy Minister



DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT *the boiler or pressure vessel*

size and type 60" x 182" Unfired Pressure Vessel. 9mb / DEYER 55

manufactured by Dominion Engineering Works Limited, Montreal, Quebec

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills, Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B-8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3429
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT

it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set

at 75 PSI Inspected on 30th January, 1960, by J.O. Allaire No. 6.0

ISSUED at TORONTO the 17th day of March, 1960

INSPECTOR

J. G. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRTEL No. 56
No. 6 PM

FORM 7



Hon. Charles Daley
Minister

No. 60-1999-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6 / Deyers6

manufactured by Dominion Engineering Works Limited, Montreal, Quebec.

(NAME AND ADDRESS OF MANUFACTURER)

for Howard Smith Paper Mills Cornwall, Ontario

(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337-5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. HT 3348
Temp 320°F
T. Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 19 60, by J.O. Allaire No.6.
ISSUED at TORONTO the 15th day of March, 19 60

INSPECTOR

J. Hutchinson
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL

DRYER No. 47
No 6 P.M.

FORM 7



Hon. Charles Daley
Minister

No. 60-2015-A

J. B. Metzler
Deputy Minister

DEPARTMENT OF LABOUR

BOILER INSPECTION BRANCH

PROVINCE OF ONTARIO

The Boilers & Pressure Vessels Act, 1951

CERTIFICATE OF INSPECTION DURING CONSTRUCTION

I CERTIFY THAT the boiler or pressure vessel

size and type 60" x 182" Unfired Pressure Vessel. PM6/De-ger 47

manufactured by Dominion Engineering Works Limited, Montreal, Quebec
(NAME AND ADDRESS OF MANUFACTURER)
for Howard Smith Paper Mills, Cornwall, Ontario
(NAME AND ADDRESS OF OWNER)

and identified by the following markings

Quebec No. B 8337.5
Max. W.P. 75 P.S.I.
T.Shell 1-1/8"

Sr.No. Ht-3425
Temp. 320°F
T.Heads 2" 2 1/2"
U-1959

has been inspected under section 15 of the Act, during construction AND I AM SATISFIED THAT
it may be operated or used safely at a maximum pressure of 75 PSI with safety-valves set
at 75 PSI Inspected on 30th January, 1960, by PROVINCE OF QUEBEC
ISSUED at TORONTO the 17th day of March, 1960 R. Rivest.

INSPECTOR

R. Rivest
CHIEF INSPECTOR

HANG THIS CERTIFICATE NEAR THE BOILER OR PRESSURE VESSEL