



LOAD BANK TEST REPORT

CUSTOMER: Central States Diesel Generators

CSDG #: 2897

Site: CSDG HQ

Pre-Start up Checks:

- 1. Eng. Oil Level
- 2. Coolant Level
- 3. Generator and load bank connected for proper volts
- 4. Safety ground connected
- 5. Circuit breaker open (off)

Test Date: _____
 Tested By: _____
 Title: Technician
 Tested At: 100%
 Ambient Temp: _____

Engine Mfg: _____

Package Serial Number: _____

KW: _____

Engine Model: _____

Engine Serial Number: _____

Control Panel Model: _____

Engine Safeties - Operational Test and/or Set Points:

Low Oil Pressure: 30 PSI

Overspeed: 2120

RPM: 1800

Hi Water Temp: _____ °F

Hours Before: _____

Hours After: _____

Test Load/Duration: 1 HR

15 MIN Min. Record Intervals

TIME	VOLTS			AMPS			FREQ HZ	LOAD KW	COOL TEMP °F	Lube Oil	FUEL PRESS	% OF LOAD	Battery Voltage
	1	2	3	1	2	3							
Warm Up							60.0						
							60.0					100%	
							60.0					100%	
							60.0					100%	
1							60.0					100%	
Cooldown				0	0	0	60.0	0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	
								0				0%	

Customer Acceptance:

By: _____

By: _____

Title: _____

Title: Technician