



REVISION				
REV	DESCRIPTION	BY	DATE	APVD
A	REVISED PER ECO #14863	MF	12/28/00	MF
B	REVISED PER ECO #15200	TA	02/15/01	TA
C	REVISED PER ECO #15413	GS	03/26/01	EPD
D	REVISED PER ECO #15528	MF	04/16/01	MF

CUSTOMER CONNECTIONS:

- TP1. FEEDWATER INLET: 1 1/2" O.D. TRI-CLAMP
- TP2. DISTILLATE TO STORAGE: 1" O.D. TRI-CLAMP
- TP3. DISTILLATE TO WASTE: 1" O.D. TRI-CLAMP
- TP4. BLOWDOWN OUTLET: 1" O.D. TRI-CLAMP
- TP5. CONTROL AIR: 1/4" F.P.T.
- TP6. EVAPORATOR DRAIN: 1" O.D. TRI-CLAMP
- TP7. STEAM INLET: 1 1/2"-150# FLANGE
- TP8. CONDENSATE OUTLET (EVAP.): 3/4"-150# FLANGE
- TP9. COOLING WATER IN (LUBE OIL): 1/2" F.P.T.
- TP10. COOLING WATER OUT (LUBE OIL): 1/2" F.P.T.
- TP11. DECARBONATOR VENT: 1 1/2" O.D. TRI-CLAMP
- TP12. CONDENSATE OUTLET (FEED HEATER): 1"-150# FLANGE
- TP13. WFI SAMPLE: 1/2" O.D. TRI-CLAMP
- TP14. COOLIN WATER IN (SAMPLE COOLER): 3/4" O.D. TRI-CLAMP
- TP15. COOLING WATER OUT (SAMPLE COOLER): 3/4" O.D. TUBE

NOTES:

1. UNIT MUST BE MOUNTED 10" ABOVE FLOOR.
2. 30" OF CLEARANCE SHOULD BE ALLOWED FOR ACCESS AROUND UNIT. 36" OF CLEARANCE IS REQUIRED IN FRONT OF PANELS.

CONTRACT NO.		MECHANICAL EQUIPMENT CO. 1615 POYDRAS ST.-1400 , NEW ORLEANS, LA. 70112	
APPROVALS	DATE	GENERAL ARRANGEMENT PES1000MSSH	
DRAWN: MF	11/17/00		
CHECKED: GS	11/17/00		
ISSUED: CN	11/17/00		
DO NOT SCALE DRAWING		SCALE: 1/12 UNLESS OTHERWISE NOTED	SHEET 1 OF 1