


BORESCOPE INSPECTION REPORT



GAS TURBINE ENGINE
CENTAUR 50
COLD END DRIVE

Engine Rating
6201SA GSC

Engine Serviceable
Yes

Inspection Performed By
GREGG ROSOFF

Inspection Date
Tuesday, January 21, 2020



This page intentionally left blank.

B O R E S C O P E I N S P E C T I O N I N F O R M A T I O N

Inspection Date	1/21/2020
Inspection Performed By	GREGG ROSSOFF
Reason For Inspection	Unplanned Inspection

Work Order #

Borecope Equipment Used (Brand/Model)	OLYMPUS I-plex
Borecope Inspection Procedure (WFM Task #)	128

P A C K A G E I N F O R M A T I O N

PD #		Package S/N	
Unit Customer Tag	2	Package Hours	0
		Package Starts	0

E N G I N E I N F O R M A T I O N

Engine GP ¹ P/N		Gas Fuel Hours	0
Engine GP S/N		Liquid Fuel Hours	0
Engine Rating	6201SA GSC	Total Hours	0
Combustion Type	SoLoNOx	Total Starts	0
Fuel Type	Dual	Next Planned Overhaul	TBD
		Running Hours	
Inspection Last Date	Tuesday, July 14, 2015	Gas Fuel Hours since last inspection	0
		Liquid Fuel Hours since last inspection	0
		Starts since last inspection	0

N O T E S

Borescope completed before Offline Compressor Wash.

B O R E S C O P E I N S P E C T I O N C H E C K L I S T



Step	Description ²	Performed			Initials & Date
		Yes	No	N/A	
1	Complete Task Risk Assessment.				GR January 21, 2020
2	Complete Job Safety Analysis.				GR January 21, 2020
3	Ensure the shutdown Gas Turbine engine is cool.				GR January 21, 2020
4	Prepare the package for a Borescope Inspection.				GR January 21, 2020
5	Perform Borescope Inspection (Record images, measurements and comments on the Borescope Inspection Report).				GR January 21, 2020
6	Return Gas Turbine engine to service.				GR January 21, 2020
7	Complete the Borescope Inspection Report (Borescope report sections populated correctly, FSR signature, Customer signature).				GR January 21, 2020
8	Print/Scan the document as a PDF. Archive the document under the WFM associated Major Assembly / Field Attachments section.				GR January 21, 2020

² For detailed step instructions, please refer to the Solar Turbines WFM (Work Force Management) internal procedure mentioned in the Equipment Information section.


EQUIPMENT DATA PLATE

Gas Turbine

Reduction GearBox




BORESCOPE INSPECTION LOCATIONS







BORESCOPE INSPECTION SUMMARY


BORESCOPE INSPECTION PICTURES


Access location Description	Picture	Inspection for	Severity / Comments
A Air Inlet Duct		a)Potential FOD b)Corrosive Pitting c)Cracks d)Excessive fouling	Normal Condition



Access location Description	Picture	Inspection for	Severity / Comments
A Air Inlet Screen		a)Potential FOD b)Cracks, damaged mesh	Normal Condition



Access location Description	Picture	Inspection for	Severity / Comments
A IGV		a)Nicks and dents. Qty and size b)Excess of fouling c)Corrosive pitting. Affected area	Minor Corrosion
A 1st Stg Compressor Blades		a)Nicks and dents. Qty and size b)Excess of fouling c)Corrosive pitting. Affected area d)Tip rub. Gap width, metal curl	Minor Corrosion




Access location Description	Picture	Inspection for	Severity / Comments
A 2nd Stg Compressor VGV	 A borescope image showing the interior of a compressor. The view is somewhat dark and grainy, with a bright light source illuminating a curved, metallic surface. There are some small, dark spots visible on the surface.	a)Nicks and dents. Qty and size b)Excess of fouling c)Corrosive pitting. Affected area	Normal Condition
A 2nd Stg Compressor Blades	 A borescope image showing the interior of a compressor. The view is dark and grainy, with a bright light source illuminating a curved, metallic surface. There are some small, dark spots visible on the surface. The number '13634-3' is visible on the left side of the image.	a)Nicks and dents. Qty and size b)Excess of fouling c)Corrosive pitting. Affected area	Normal Condition



Access location Description	Picture	Inspection for	Severity / Comments
B Compressor Exit GV		<p>a)Nicks and dents. Qty and size</p> <p>b)Excess of fouling</p> <p>c)Corrosive pitting. Affected area</p>	<p>Minor</p> <p>Corrosion</p>

Access location Description	Picture	Inspection for	Severity / Comments
B Injectors		a)Pilot Center Erosion b)Fuel hole contaminated or blocked c)Cracks, Qty & Size d)Liquid: broken spoke	Normal Condition


Access location Description	Picture	Inspection for	Severity / Comments
B Combustor Interior		a)Cracks, Qty, length, orientation b)Thermal Erosion c)Hot Spots d)Buckling or warpage	Normal Condition
B Torch Tube		a)Thermal erosion	Normal Condition

Access location Description	Picture	Inspection for	Severity / Comments
B 1st Stg Turbine Nozzles		a)Cracks, Qty, length, orientation b)Thermal Erosion. Depth, Area c)FOD, Area	Normal Condition
B 1st Stg Turbine Blades		a)Cracks, Qty, length, orientation b)Thermal Erosion. Depth, Area c)FOD, Area d)Tip rub, Gap width	Normal Condition

Access location Description	Picture	Inspection for	Severity / Comments
C 2nd Stg Turbine Nozzles		a)Cracks, Qty, length, orientation b)Thermal erosion, Depth, Area c)FOD, Area	Normal Condition
C 2nd Stg Turbine Blades		a)Cracks, Qty, length, orientation b)Thermal Erosion. Depth, Area c)FOD, Area d)Tip rub, Gap width	Minor Corrosion
D 3rd Stg Turbine Nozzles		a)Cracks, Qty, length, orientation b)Thermal erosion, Depth, Area c)FOD, Area	Normal Condition

Access location Description	Picture	Inspection for	Severity / Comments
D 3rd Stg Turbine Blades		a)Cracks, Qty, length, orientation b)Thermal Erosion. Depth, Area c)FOD, Area d)Tip rub, Gap width	Normal Condition
VG IGV		a)Cracks b)Lever arms bent c)Grommet out of position on unison ring d)Corrosion	Normal Condition

Gearbox



Normal Condition



Access location Description	Picture	Inspection for	Severity / Comments
			

C O N C L U S I O N

The Engine appears to be in serviceable condition at this time. Minor corrosion/oxidation was observed in the forward and aft sections of the compressor as well as the second stage turbine blades, this is due to the turbine being stored for over four years in a harsh environment.

R E C O M M E N D A T I O N

Please continue to monitor engine condition and preservation status if continued storage is required.

BORESCOPE INSPECTION OF GAS TURBINE ENGINE GENERAL OBJECTIVES

The gas turbine borescope inspection is an internal inspection performed by a trained specialist who assesses the condition of the gas turbine components. This inspection is performed using an instrument specifically designed to examine the gas path, via the access ports positioned along the engine, from the air inlet to the exhaust.

These inspections are one of the primary diagnostic methods for maintaining turbo-machinery. Both rigid and flexible fiberscopes are used in conjunction with especially formed guide tubes to inspect the internal stationary and rotating components. Primary goals are to detect early signs of wear or impending failure. The major benefits of the inspection include equipment condition awareness and effective scheduling of any necessary maintenance interventions. In addition, greater reliability / longevity can be achieved through internal inspections, as well as reducing the potential of severe equipment damage.

The operating gas turbine engine components, by design, are exposed to high thermal and mechanical constraints. Internal inspections are thus necessary to determine if wear or thermal erosion has occurred. In addition, these inspections will quantify if any foreign object damage (FOD) or corrosion has occurred, as well as assessing internal components for thermal deterioration, cracking or distortion.

While every effort is made to examine all accessible parts of the engine, some areas are not accessible through a borescope inspection. Therefore, a borescope inspection should not be considered to be the ultimate method to assess an engine's health.

This borescope inspection has been performed following a Hierarchical Task Analysis procedure exposed in TL 21.7/100.

SOLAR TURBINES INSPECTOR SIGNATURE / DATE

Inspector Name: **GREGG ROSSOFF**

Inspector Email Address:

Inspector Phone Number: