



SPS Final Test Report Vibration and Alignment

Point	1x(in/s)	2x(in/s)	Overall(in/s)
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
M1			
M2			
M3			
M4			
M5			
M6			

Work Order Number: 107179638		Date: 12-13-19
Customer: XTO Longhorn Comp St. 1 of 2		
Project: 500002097H		
SPS Skid Type: FM1000		S/N: 15083433
Motor HP: 60	Mfg: GE	S/N: LNFT326U010
Pump Type: 2SE 4200		S/N:
Number Stages: 23		S/N:
500002115-H		S/N: 15074163
		S/N:
Thrust Chamber: AL-185108		S/N: 15057642
Motor Coupling Type: Dodge		
Pressure & Flow @ Q Min		Motor Amps
Suction: 67	(psi)	Phase 1: 43
Discharge: 388	(psi)	Phase 2: 44
Flowrate: 51	(bpd/gpm)	Phase 3: 44
Pressure & Flow @ BEP		Motor Amps
Suction: 65	(psi)	Phase 1: 51
Discharge: 359	(psi)	Phase 2: 51
Flowrate: 82	(bpd/gpm)	Phase 3: 48
Pressure & Flow @ Q Max		Motor Amps
Suction: 65	(psi)	Phase 1: 51
Discharge: 291	(psi)	Phase 2: 58
Flowrate: 108	(bpd/gpm)	Phase 3: 52
Specific Gravity	Max Amps	70
Motor temp 78	Motor volts 460	Motor RPM/Hz 3575/60
Motor eff rating	Pwr factor rating	
Length of Test: 30	(min.)	
Ambient Temp: 65	deg F	
TC Operating Temp: 72	deg F	

Certification of test within acceptable limits

X MR
 Pass Fail

Notes

NTC Only - Record total indicator runout on coupling. Max tolerance is .0035

Coupling Alignment Dimensions (thousandths inch)

See Field Service Manual for Misalignment Limits

Offset Misalignment **Angular Misalignment**

Vibration Points

Suction/Pump Base Alignment

Clearance (thousandths inch)

- _____ in @ 12:00
- _____ in @ 3:00
- _____ in @ 6:00
- _____ in @ 9:00

All dimensions to be equal

Vibration limits are 0.156 in/s @ 1x and 0.100 in/s at any other frequency.



Baker Hughes, Incorporated

844 W Lowry Rd
Claremore, OK, USA

Tested to API RP11S2 1997

Tested to BHI Engineering Specification ES 517

Stage Type: TE-4200:COMP Stages: 23
Serial Number: 15083433 NEW Pump
Well Name: none Well ID: none
Customer: LONG 1
Remarks: none

Date Tested: 12/13/2019
Tested By: ritmikl

RAW DATA	Test Point	Speed (rpm)	Temp (degF)	Flow (GPM)	Pin (psi)	Pout (psi)	Torque (Ft-lbs)
	1	2097	75	0	66	306	0.8
	2	2100	75	22.9	66	319	0.9
	MIN	2397	75	51.2	67	388	0.9
	BEP	2395	75	81.8	65	359	0.8
	MAX	2394	75	108	65	291	0.8
	6	1795	75	98.9	65	140	0.8
	7	1795	75	107	66	117	0.8

BPD and HEAD are corrected to density=1.0
Rate, Head and BHP are corrected to 3500 rpm

TEST DATA	Test Point	Flow (BPD)	Head (ft)	Power (HP)	Eff (%)
	1	0	67.0	-0.23	100
	2	1308	70.4	-0.23	100
	MIN	2564	68.7	-0.18	100
	BEP	4099	62.9	-0.17	100
	MAX	5414	48.4	-0.17	100
	6	6610	28.6	-0.3	100
	7	7153	19.6	-0.29	100


PERCENT DEVIATION/LIMITS

Deviation (%) / API Limit (%)

MIN	2600	-3 / ±5.0%	* -107.2 / ±8.0%	
BEP	4200	-.1 / ±5.0%	* -104.7 / ±8.0%	50.9 / -10.0%
MAX	5400	.1 / ±5.0%	* -105.4 / ±8.0%	

*Indicates Failed Limit

TE-4200:COMP Pump Performance- ONE stage @ 3500 RPM and SG=1.0





Elapsed Time (hh:mm:ss)

00:10:52

File Name

10583433-20191213_0649

Serial Number

10583433

Part Number

500002097H

Work Order

107179638

EXIT

STOP

Location	1	2	M3	M1	M2	M5	M4	M6	3	4	5	6	7	8	9	10	11	12	13	14	15
Overall Vibration (in/s)	0.057	0.037	0.063	0.039	0.041	0.043	0.041	0.043	0.041	0.056	0.072	0.057	0.035	0.031	0.003	0.026	0.036	0.038	0.004	0.004	0.042
1X Vibration (in/s)	0.009	0.020	0.011	0.012	0.001	0.022	0.012	0.002	0.009	0.008	0.014	0.033	0.011	0.010	0.001	0.010	0.013	0.014	0.002	0.002	0.017
2X Vibration (in/s)	0.038	0.003	0.009	0.012	0.000	0.016	0.017	0.001	0.019	0.020	0.006	0.018	0.013	0.005	0.000	0.003	0.005	0.007	0.000	0.000	0.019

Speed (RPM) **2400**

1X Max Vibration 0.0327

1X Vibration <= 0.1560 in/s ●

non-1X Max Vibration 0.038


non-1X Vibration <= 0.100 in/s ●

Motor Amps:

Phase 1 43

Phase 2 44

Phase 3 44



Test Result

PASS

PRINT SCREENSHOT



Elapsed Time (hh:mm:ss)

00:09:02

File Name
10583433-20191213_0649

Serial Number
10583433

Part Number
500002097H

Work Order
107179638

EXIT

STOP

Location	1	2	M3	M1	M2	M5	M4	M6	3	4	5	6	7	8	9	10	11	12	13	14	15
Overall Vibration (in/s)	0.060	0.038	0.053	0.041	0.027	0.045	0.042	0.028	0.041	0.054	0.065	0.058	0.043	0.041	0.002	0.030	0.047	0.047	0.004	0.004	0.083
1X Vibration (in/s)	0.003	0.018	0.006	0.010	0.001	0.017	0.011	0.002	0.008	0.010	0.014	0.031	0.014	0.007	0.001	0.013	0.018	0.019	0.002	0.002	0.023
2X Vibration (in/s)	0.040	0.004	0.011	0.012	0.001	0.016	0.016	0.001	0.019	0.020	0.010	0.014	0.017	0.005	0.000	0.005	0.005	0.006	0.000	0.000	0.018

Speed (RPM) **2397**

1X Max Vibration 0.0311 1X Vibration <= 0.1560 in/s ●


non-1X Max Vibration 0.040 non-1X Vibration <= 0.100 in/s ●

Motor Amps:

Phase 1 **51**

Phase 2 **51**

Phase 3 **48**



Test Result

PASS

PRINT SCREENSHOT



Elapsed Time (hh:mm:ss)

00:07:28

File Name
10583433-20191213_0649

Serial Number
10583433

Part Number
500002097H

Work Order
107179638

EXIT

STOP

Location	1	2	M3	M1	M2	M5	M4	M6	3	4	5	6	7	8	9	10	11	12	13	14	15
Overall Vibration (in/s)	0.064	0.036	0.053	0.039	0.020	0.044	0.043	0.020	0.042	0.052	0.061	0.054	0.045	0.035	0.002	0.030	0.045	0.046	0.004	0.004	0.051
1X Vibration (in/s)	0.008	0.017	0.008	0.010	0.002	0.016	0.009	0.001	0.008	0.010	0.012	0.030	0.015	0.008	0.001	0.013	0.019	0.019	0.002	0.002	0.022
2X Vibration (in/s)	0.044	0.003	0.011	0.014	0.001	0.007	0.021	0.002	0.023	0.025	0.011	0.018	0.018	0.002	0.000	0.003	0.006	0.008	0.000	0.000	0.026

Speed (RPM) **2395**

1X Max Vibration 0.0296 1X Vibration <= 0.1560 in/s ●


non-1X Max Vibration 0.044 non-1X Vibration <= 0.100 in/s ●

Motor Amps:

Phase 1 **51**

Phase 2 **58**

Phase 3 **52**



Test Result

PASS

PRINT SCREENSHOT

Test Point
MAX