

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS

(Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)

As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

113

1. Manufactured and certified by Himile Mechanical Manufacturing Co., Ltd. No.2069,Himile Road Mishui Hitec Park Gaomi, Shandong Province, 261500 PRC.

(Name and address of Manufacturer)

2. Manufactured for Cameron

(Name and address of Purchaser)

3. Location of installation Not Known

(Name and address)

4. Type Vertical 437101 NA HMS00445,Rev.12(0) 5114 2014
(Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (Drawing number) (National Board number) (Year built)

5. ASME Code, Section VIII, Division 1 2013 NA NA [Special Service per UG-120(d)]

6. Shell: SA-106 Gr.B/C / SA 350 LF2 CLASS 1 0.969" 0 22.062" 7'-0" [Edition and Addenda, if applicable (date)] [Code Case numbers] [Nominal thickness] [Corr. allow.] [Inner diameter] [Length (overall)]
(Material spec. number, grade) (Spec. no., grade)

Body Flanges on Shells

| No. | Type | ID | OD | Flange Thk. | Min Hub Thk. | Material | How Attached | Location | Bolting | | |
|-----|------|----|----|-------------|--------------|----------|--------------|----------|-----------|------------------|----------------------|
| | | | | | | | | | Num.&Size | Bolting Material | Washer (OD, ID, thk) |
| NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA |

7. Seams: S None 100 NA NA Sngl. Type1 Spot 85 1
[Long. (welded, dbl., sngl., lap, butt)] [R.T. (spot or full)] [Eff. %] [H. T. temp.] [Time, hr] [Girth. (welded, dbl., sngl., lap, butt)] [R.T. (spot or full)] [Eff. %] [No. of courses]8. Heads: (a) Material SA-516 Gr.70 N (b) Material SA-516 Gr.70
(Spec. no., grade) (Spec. no., grade)

| Location (Top, Bottom, Ends) | Minimum Thickness | Corrosion Allowance | Crown Radius | Knuckle Radius | Elliptical Ratio | Conical Apex Angle | Hemispherical Radius | Flat Diameter | Side to Pressure (Convex or Concave) |
|------------------------------|-------------------|---------------------|--------------|----------------|------------------|--------------------|----------------------|---------------|--------------------------------------|
| (a) Top | 1.079" | 0.125" | NA | NA | 2:1 | NA | NA | NA | Concave |
| (b) Bottom | 0.82" | 0 | NA | NA | 2:1 | NA | NA | NA | Concave |

Body Flanges on Heads

| | Location | Type | ID | OD | Flange Thk. | Min Hub Thk. | Material | How Attached | Bolting | | |
|-----|----------|------|----|----|-------------|--------------|----------|--------------|-----------|------------------|----------------------|
| | | | | | | | | | Num.&Size | Bolting Material | Washer (OD, ID, thk) |
| (a) | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA |

9. MAWP 1440psi NA at max. temp. 130°F NA (External) (Internal) (External)Min. design metal temp. -20°F at 1440psi Hydro., pneu., or comb. test pressure Hydro. 1872psi.Proof test NA.

10. Nozzles, inspection, and safety valve openings:

| Purpose (Inlet, Outlet, Drain etc.) | No. | Diameter or Size | Type | Material | | Nozzle Thickness | | Reinforcement Material | Attachment Details | | Location (Insp.Open.) |
|-------------------------------------|-----|------------------|-------------|----------|--------|------------------|-------|------------------------|--------------------|--------|-----------------------|
| | | | | Nozzle | Flange | Nom. | Corr. | | Nozzle | Flange | |
| Gas Inlet(Inspection) | 1 | NPS6 | CI 600 lwn. | / | SA-105 | 1.378" | 0 | Inherent | Fig.UW-16.1(c) | No NDE | Shell |
| See attached U-4 Form | | | | | | | | | | | |

11. Supports: Skirt Yes Lugs NA Legs NA Other No Attached welded to head
(Yes or no) (Number) (Number) (Describe) (Where and how)12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: (6)24" CLOSURES R&M ENERGY SYSTEMS XC452 ASME-U
(Name of part, item number, Manufacturer's name and identifying stamp)

(1)Impact test exempted according to UG-20(f),UCS-66(c).

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization Number 39,452
expires April 7,2016.Date Jul.14,2014 Co. name Himile Mechanical Manufacturing Co.,Ltd. Signed 15Jul14 (Manufacturer) 15Jul14 (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Himile Mechanical Manufacturing Co., Ltd. at No.2069,Himile Road Mishui Hitec Park Gaomi, Shandong Province 261500 PRC.
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by
SGS United Kingdom Limited.have inspected the component described in this Manufacturer's Data Report on 15Jul14, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.Date 15Jul14 Signed 15Jul14 Commissions NB 13940 A
(Authorized Inspector) [National Board (incl. endorsement)]

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET

As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Himile Mechanical Manufacturing Co.,Ltd. No.2069,Himile Road Mishui Hitec Park Gaomi, Shandong Province, 261500 PRC.

(Name and address of Manufacturer)

2. Manufactured for Cameron
(Name and address of Purchaser)

3. Location of installation Not Known
(Name and address)

4. Type: Vertical Vessel 437101
(Horizontal, vertical, or sphere) (Tank, separator, heat exch., etc.) (Manufacturer's serial number)

NA HMS00445,Rev.12(0) 5114 2014
(CRN) (Drawing Number) (National Board number) (Year built)

Data Report

Item Number

Remarks

| Purpose (Inlet, Outlet, Drain etc.) | No. | Diameter or Size | Type | Material | | Nozzle Thickness | | Reinforcement Material | Attachment Details | | Location (Insp.Open.) |
|---|-----|---------------------|-------------|----------|--------|------------------|-------|---------------------------|--------------------|--------|--------------------------|
| | | | | Nozzle | Flange | Nom. | Corr. | | Nozzle | Flange | |
| Gas Outet (Inspection) | 1 | NPS6 | CI 600 lwn. | / | SA-105 | 1.378" | 0 | Inherent | Fig.UW-16.1(c) | No NDE | Shell |
| Lower Outlet/Drain | 1 | NPT1 | w.e. | SA-105 | / | 0.205" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| Lower Level Control | 1 | NPT2 | w.e. | SA-105 | / | 0.305" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| Lower Level Gauge | 1 | NPT2 | w.e. | SA-105 | / | 0.305" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| Upper Outlet/Drain | 1 | NPT1 | w.e. | SA-105 | / | 0.205" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| Upper Level Control | 1 | NPT2 | w.e. | SA-105 | / | 0.305" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| Upper Level Gauge | 1 | NPT2 | w.e. | SA-105 | / | 0.305" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| PSV | 1 | NPT1 | w.e. | SA-105 | / | 0.205" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| DPI | 2 | NPT1/2 | w.e. | SA-105 | / | 0.157" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |
| PI | 1 | NPT1/2 | w.e. | SA-105 | / | 0.157" | 0 | Inherent | Fig.UW-16.1(bb) | / | NA |

Certificate of Authorization: Type U No. 39,452 Expires April 7,2016

Date Jul.14,2014 Name Himile Mechanical Manufacturing Co.,Ltd. Signed 14/4
(Manufacturer) (Representative)

Date 15Jul14 Name Woy Commission NB13940A
(Authorized Inspector) [National Board(ind. endorsements)]

SO No 1451913-1

PO No 4510290882 FORM U-2A MANUFACTURER'S PARTIAL DATA REPORT (ALTERNATE FORM)

A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer

As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by R&M ENERGY SYSTEMS 10906 FM 2920 TOMBALL, TEXAS 77375

(Name and address of Manufacturer)

2. Manufactured for NATCO US/CAMERON PO BOX 3101 HOUSTON, TX 77253-3101

(Name and address of Purchaser)

3. Location of Installation UNKNOWN

(Name and address)

4. Type: (6) 24" CLOSURES

(Description of vessel part (shell, two-piece head, tube bundle))

XC452 THRU XC457

N/A

(CRN)

N/A

1451913-1R1

R&M ENERGY SYSTEMS

2014

(National Board Number)

(Drawing Number)

(Drawing prepared by)

(Year Built)

5. ASME Code, Section VIII, Div. 1 2013 EDITION

(Edition and Addenda (Date))

N/A

N/A

(Special service per UG-120(d))

6. Shell (a) No. of course(s) 1 (b) Overall length (ft. and in.): 1-00.

| Course(s) | | | Material | Thickness, in. | | | Long Joint (Cat. A) | | | Circum. Joint (Cat. A, B, & C) | | | Heat Treatment | | | | |
|-----------|---------------|---------------|---------------------|----------------|-------|------|---------------------|-------|------|--------------------------------|------|-------|----------------|------|------|-----------|------|
| No. | Diameter, in. | Length, ft+in | Spec./Grade or Type | Nom. | Corr. | Type | Full, | Spot, | None | Eff. | Type | Full, | Spot, | None | Eff. | Temp., F. | Time |
| 1 | 22.062 | 1-00. | SA 350 LF2 | 1.000 | 0.125 | S | NONE | | | 1 | S | NONE | | | 1 | N/A | N/A |
| | | | CLASS 1 | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |

Body Flanges on Shells

| No. | Type | ID | OD | Flange Thk | Hub Thk | Material | How Attached | Location | Num & Size | Bolting Material | Bolting | | | Washer (OD, ID, Thk) | Washer Material |
|-----|------|----|----|------------|---------|----------|--------------|----------|------------|------------------|---------|--|--|----------------------|-----------------|
| | | | | | | | | | | | | | | | |
| N/A | | | | | | | | | | | | | | | |

7. Heads: (a) SA 516-70 N (b) N/A

(Mat'l Spec. no., Grade or Type)(H.T. - Time and Temp.)

(Mat'l Spec. no., Grade or Type)(H.T. - Time and Temp.)

| Location (Top, Bottom) | | Thickness, in. | | Radius, in. | | Elliptical | Conical | Hemispherical | Flat | Side to Pressure | | Category A | | | |
|------------------------|-----|----------------|-------|-------------|---------|------------|-----------|---------------|----------|------------------|---------|------------|-------------------|------|---|
| Ends) | | Mln. | Corr. | Crown | Knuckle | Ratio | Apx Angle | Radius | Diameter | Convex | Concave | Type | Full, Spot, None. | Eff. | |
| (a) | TOP | 1.079 | 0.125 | ---- | ---- | 2:1 | ---- | ---- | ---- | | | X | S | NONE | 1 |
| (b) | | | | | | | | | | | | | | | |

Body Flanges on Heads

| Location | Type | ID | OD | Flange Thk | Hub Thk | Material | How Attached | Num & Size | Bolting Material | Bolting | | | Washer (OD, ID, Thk) | Washer Material |
|----------|------|----|----|------------|---------|----------|--------------|------------|------------------|---------|--|--|----------------------|-----------------|
| | | | | | | | | | | | | | | |
| (a) | N/A | | | | | | | | | | | | | |

8. MAWP 1440 PSI @ max temp.= 130 °F. Min Design Metal Temp -20 °F at 1440 PSI

Internal External

Internal External

9. Impact test Yes - CAP & HUB At a test temp of -51 & -50 °F

[Indicate yes or no and the component(s) impact tested]

10. Hydro., pneu., or comb. Test pressure SEE REMARKS Proof Test: N/A

11. Nozzles, inspection, and safety valve openings: UG-125(a) At PSIG

| Purpose (Inlet, Outlet, Drain, etc.) | No. | Dia. or Size, in. | Type | Material | Nozzle | Flange | Nom. | Corr. | Reinforcement | How Attached | Location (Insp. Open.) |
|---|-----|----------------------|------|----------|--------|--------|------|-------|---------------|--------------|---------------------------|
| SEE REMARKS | | | | | | | | | | | |

12. Identification of part(s) PAV 1 1/2" NPT TH'D SA 350 LF2 CL1 N/A N/A INHERENT INT THD SHELL

| Name of Part | Qty. | Line No. | Mfg's. Identification No. | Mfg's. Dwg No. | CRN | National Board No. | Year |
|--------------|------|----------|---------------------------|----------------|-----|--------------------|------|
| N/A | | | | | | | |

13. Supports: Skirt — Lugs — Legs — Others — Attached — (Where and How)

(Yes or No)

(Number)

(Number)

(Describe)

(Where and How)

14. Remarks: THIS TEMPERATURE APPLICABLE TO CLOSURE METAL COMPONENTS ONLY. ACTUAL SERVICE TEMPERATURE IS DETERMINED BY TEMPERATURE LIMITATIONS OF O-RING MATERIAL.

UG-120,c,2 DESIGN & CALCULATION BY R&M ENERGY SYSTEMS. CLOSURE ASSEMBLY IS NOT HYDROSTATICALLY TESTED, PRESSURE ALERT VALVE FURNISHED.

FORM U-2A (Back)

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this pressure vessel part conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate of Authorization No.10052 Expires: July 16, 2014

Date: 02/28/14 Name: R&M ENERGY SYSTEMS Signed: Jimmy R. Davis
(Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by The Hartford Steam Boiler Inspection and Insurance Company of CONNECTICUT have inspected the pressure vessel part described in this Manufacturer's Data Report on 2/28, 2014, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel part in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel part described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 2/28/14

Signed: Benjamin J. Grupe

(Authorized Inspector)

Commissions: NB397EAN TX1868

[National Board (incl. endorsements)]