

FORM R-1, REPORT OF WELDED ☒ REPAIR OR ☐ ALTERATION  
as required by the provisions of the National Board Inspection Code

1. Work performed by CERAMIC COATING COMPANY 4-38700  
(name of repair or alteration organization) (P.O. no., job no., etc.)

123 BANKLICK ROAD, NEWPORT, KY 41072  
(address)

2. Owner (ORIGINAL) HOFFMANN-LAROCHE, INC.  
(name)

NUTLEY, NJ  
(address)

3. Location of installation JONES-HAMILTON CO.  
(name)

NEWARK, CA 94560  
(address)

4. Unit identification: PRESSURE VESSEL Name of original manufacturer THE PFAUDLER CO.  
(boiler, pressure vessel)

5. Identifying nos.: R173-0228 32100 S172-6889 1973  
(mfr's. serial no.) (original National Board no.) (jurisdiction no.) (other) (year built)

6. Description of work: Jacket was removed so inner vessel could be glass lined.  
(use back, separate sheet, or sketch if necessary)

Jacket was reinstalled after glass lining.

JACKET HYDROSTATIC

Pressure test, if applied xxxxxxx 135 psi

7. Replacement Parts. Attached are Manufacturers' Partial Data Reports properly identified and signed by Authorized Inspectors for the following items of this report:

8. Remarks:

Q.C. 4148

C.O. 16370



### DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. \_\_\_\_\_ to use the \_\_\_\_\_ symbol expires \_\_\_\_\_, 19\_\_\_\_.

Date \_\_\_\_\_, 19\_\_\_\_ Signed \_\_\_\_\_  
(name of organization) (authorized representative)

### CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of \_\_\_\_\_ and employed by \_\_\_\_\_ of \_\_\_\_\_ has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date \_\_\_\_\_, 19\_\_\_\_ Signed \_\_\_\_\_ Commissions \_\_\_\_\_  
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

### CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship on this REPAIR conform to the National Board Inspection Code.  
(repair or alteration)

Certificate of Authorization no. 16284 to use the U symbol expires 12 JAN, 1993.

Date 8/5, 1992 Signed Ceramic Coating Company Signed Robert R. Schultz  
(repair or alteration organization) (authorized representative)

### CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Kentucky and employed by Commercial Union Insurance Company of Boston, MA has inspected the work described in this report on 8-5-92, 19\_\_\_\_ and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date 8-5, 1992 Signed James R. Allen Commissions NB9608 Ky 992  
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)



**PFAUDLER**  
SYBRON CORPORATION  
ROCHESTER, N.Y. AND ELYRIA, OHIO, U.S.A.

MFR R173-0228 NTL BD 32100  
YR. BUILT 1978 INS  
W INT PR 100 PSI AT 650  
JKT PR 90 PSI AT 350  
JKT PR 90 PSI W/INT 350  
S172-6889

MATH: CLASSET® &/OR NUCERN®  
REFER TO PFAUDLER LITERATURE FOR  
CORROSION AND TEMPERATURE LIMITATIONS  
THIS PRODUCT MAY BE COVERED BY ONE OR MORE OF THESE PATENTS:  
2,714,024; 2,808,176; 2,808,657; 2,811,339; 2,870,982; 3,010,601; 3,051,519; 3,062,733;  
3,761,626; 3,765,868; 3,834,870; 3,866,712; 3,997,076; 4,425,582. (U.S. PATENTS  
PENDING)

ROCHESTER  
CODE YZ1-588

REPAIRED BY  
RAPID COATING CO  
FV 100 PSI AT 650  
-20 PSI AT 100  
90 PSI AT 350  
90 PSI W/INT 350  
-20 PSI AT 90  
HT2000  
4.38700 YR BUILT 73  
PFAUDLER 32100 R173-0228  
S172-6889  
REPAIRED 1992  
16370  
NEWPORT, KENTUCKY, USA







# FORM 1-1 MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS

As required by the Provisions of the ASME Code Rules, Section VIII, Division I

1. Manufactured by THE PFAUDLER CO., ROCHESTER, NEW YORK, U. S. A.

(Name and address of Manufacturer)

2. Manufactured for Hoffmann-LaRoche, Inc., Nutley, New Jersey

(Name and address of Purchaser)

3. Type Vertical Jacketed Kind R173-0228 (Mfrs. Serial) (State & State No.) Natl. Bd. No. 32100 Yr. Built 1973

Items 4-7 incl. to be completed for single wall vessels (such as air tanks), jackets of jacketed vessels, or shells of heat exchangers.

4. SHELL Material SA515GR.65 65,000 Nominal Thickness 3/8 Corrosion Allowance 0 In. Diam 5 Ft. 6 In. Length 6 Ft. 4 In.

5. SEAMS Long DBFW H I No R I No Sectioned No Efficiency 70 % If riveted describe seams fully on reverse side of form.

6. HEADS (a) Material SA515 GR.65 65,000 (b) Material SA515 GR.65 65,000 (c) Material SA515 GR.65 65,000

Location Bottom Thickness 7/16" Crown Radius 66" Knuckle Radius 4" Elliptical Ratio 2:1 Conical Apex Angle 0 Hemispherical Radius 0 Flat Diameter 0 Side to Pressure Concave

If removable, bolts used (a) (Material, Spec. No., T.S., Size, Number) (b) Other fastening (Describe or Attach Sketch)

7. STAY BOLTS (Material) If hollow (Size of Hole) Attachment (Threaded, Welded) Pitch (Horiz.) X (Vert.) Diam (Nominal)

8. JACKET CLOSURE Pfaudler sealer welded per figure UA-104 (b-2) (Describe as over & weld, bar, etc. If bar give dimensions, if bolted describe or sketch)

9. Constructed for max. allowable working press. 90 psi at max. temp. 350 °F. Min. temp. (when less than -20°) 0 °F. Hydrostatic Test Press 135 psi

Items 10 and 11 to be completed for tube sections.

10. TUBE SHEETS Stationary Material (Kind & Spec. No.) Diam. In. Thickness In. Attachment (Welded, Bolted) Floating Material (Kind & Spec. No.) Diam. In. Thickness In. Attachment

11. TUBES Material O.D. In. Thickness In. Inches or Gage Number Type (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

12. SHELL Material SA285GR.B 50,000 Nominal Thickness 11/16 Corrosion Allowance 0 In. Diam 5 Ft. 0 In. Length 5 Ft. 8 In.

13. SEAMS Long DBFW H I No R I No Sectioned No Efficiency 70 % If riveted describe seams fully on reverse side of form.

14. HEADS (a) Material SA285-B 50,000 (b) Material SA285-B 50,000 (c) Material SA285-B 50,000

Location XXXXXX Thickness 11/16" Crown Radius 0 Knuckle Radius 0 Elliptical Ratio 2:1 Conical Apex Angle 0 Hemispherical Radius 0 Flat Diameter 0 Side to Pressure Concave

(b) XXXX Bot. Thickness 5/8" Crown Radius 0 Knuckle Radius 0 Elliptical Ratio 2:1 Conical Apex Angle 0 Hemispherical Radius 0 Flat Diameter 0 Side to Pressure Both

(c) Floating (Material, Spec. No., T.S., Size, Number) Other fastening (Describe or Attach Sketch)

15. Constructed for max. allowable working press. 100 psi at max. temp. 650 °F. Min. temp. (when less than -20°) 0 °F. Hydrostatic Test Press 100 psi

Items below to be completed for all vessels where applicable.

16. SAFETY VALVE OUTLETS Number Over pressure prot. to be installed in connecting piping

Purposes (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
Inlet	7	2"4"8"	L.J.Flq.	Case 1251	150#	-	W
Outlet	1	4"	L.J.Flq.	Case 1251	150#	-	W
Jacket	11	1 1/2"2"3"	Cplg.	SA216 WCA X Hvy.	-	-	W
Drive	1	4-3/8"	L.J.Flq.	Case 1251	150#	-	W



## FORM U-1 (back)

CUSTOMER ORDER NO. E378145E Del. Bldg. 104 Pos. No. Gen. Spare-769 Equip. Code  
 PFAUDLER ORDER NO. No. YZE-388 MOE-2279 DRV-2170

18. INSPECTION: Manholes, No. 1 Size 30" Location Top Head W/14X18" M.H. & 4" Obs. Gl.  
 OPENINGS: Handholes, No.      Size      Location       
 Threaded, No.      Size      Location     

19. SUPPORTS: Skirt, No. 0 Location      Feet, 4 Other None Attached Welded to jacket head.  
 (Yes or No) (Number) (Number) (Describe) (Where and How)

20. REMARKS Jacketed glassed steel vessel for chemical service. Jacket  
also rated for 90 psi with full vacuum in tank @ 350°F.  
Temperature requirements greater than 350°F. necessitate a reduction  
in jacket design pressure.  
Jacket for non-corrosive service.

(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooker, etc.)

(State contents of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division I.

Date July 10 1973 Signed THE PFAUDLER CO. By Michael DiBella  
 (Manufacturer)

Certificate of Authorization Expires 198 12-31-73

N.B.# 32100

### CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY THE PFAUDLER CO. at ROCHESTER, NEW YORK

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province New York and employed by Hartford Steam Boiler & Insp. Co. of Hartford, Conn. have inspected the pressure vessel described in this manufacturer's data report on June 28 1973 and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date July 16 1973 Commissions N.B.#6658, Ohio, Pa. #WC1849  
Russell B. Miller Nat'l. Board, State, or Province and No.  
 Inspector's Signature

### CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province      and employed by      of      have compared the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to as data items      not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of      psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date      19     Commissions       
     Nat'l. Board, State, or Province and No.  
 Inspector's Signature




THE CERAMIC COATING COMPANY

Date: 8/12/92


PLUG LOCATION CHART

Customer: JONES-HAMILTON Shop Order No. 4-38700 No. Plugs 0  
Description: RAGO 7000 Glass Type HT2000 Plug Type —

Top Head (outside view)



180°		90°				270°		180°



Bottom Head (outside view)

Report by: RLT

