



APPROVED FOR MANUFACTURE

MWO	DATE	BY
PURCHASING <input type="checkbox"/>	RECEIVING <input type="checkbox"/>	SHOP <input type="checkbox"/>

REVISIONS

NO	DESCRIPTION	DATE	BY
1	ADDED SCENARIO 2	02 SEP 14	LMO
2	REVERSED N1 & N2; ADDED SHIM	03 SEP 14	LMO
3	SUPPORTS WERE BOLT ON TYPE	18 SEP 14	LMO



NB

XXXX  
CERTIFIED BY: ENERQUIP, LLC  
M.A.W.P.

MS

SHELL SIDE: 150 PSIG @ 375 °F  
TUBE SIDE: 150 PSIG @ 375 °F  
MIN. DESIGN METAL TEMP.

U  
W

SHELL SIDE: -20 °F @ 150 PSIG  
TUBE SIDE: -20 °F @ 150 PSIG  
SERIAL NO:  
BUILT: CRN:  
TAG NO:

EXTERIOR SIDE FINISH: MILL FINISH  
PRODUCT SIDE FINISH: MILL FINISH  
SHELL SIDE MATERIAL: 304L  
TUBE SIDE MATERIAL: 316L

NOZZLE SCHEDULE		
LABEL	TYPE	QTY
N1	TUBE INLET - 2 SANITARY CONNECTION	1
N2	TUBE OUTLET - 2 SANITARY CONNECTION	1
N3	SHELL INLET - 6 NPS 150# ANSI RF SO W/(2) 1 NPT 3000# CLASS AUXILIARY PORTS & HEX PLUGS	1
N4	SHELL OUTLET - 6 NPS 150# ANSI RF SO W/(2) 1 NPT 3000# CLASS AUXILIARY PORTS & HEX PLUGS	1
N5	SHELL VENT - 1 NPT 3000# CLASS W/HEX PLUG	1
N6	SHELL DRAIN - 1 NPT 3000# CLASS W/HEX PLUG	1

PREPARED BY <b>L. LOPEZ WICKAK</b>	DATE <b>9-18-14</b>
CHECKED <b>D. FREEMAN</b>	DATE <b>9-18-14</b>
ENGINEER <b>[Signature]</b>	DATE <b>9-18-14</b>

16 NPS x 120 BEUH  
MWO 17230 34791R4  
SCENARIO 2



SIZE <b>A</b>	TEMA B	DRAWING NO. <b>268838</b>	REVISION <b>3</b>
1965.54 LBS.		SHEET 1 OF 3	