

LOIT CORPORATION

WILSCHFEGGER INDUSTRIES COMPANY
FIBER SYSTEM DIVISION DALTON, MA., U.S.A. 01226

POSIFLOW "60" CLEANERS CERTIFICATION SHEET

IDENTIFICATION

CUSTOMER Flambeau Paper Corp.

ADDRESS Park Falls, WI

CUST. ORDER NO. 85000014-6

CUSTOMER EQUIP. NO. _____

CERTIFIED BY [Signature] /David B. Grimes

CUSTOMER I.D. NO. 09460

SIZE PB-20

MODEL NO. _____

*SERIAL NO. PB-299

DATE May 28, 1992

JONES S.O. 922708A- 79

TITLE Sr. Product Engineer

FLOW CLEANERS

GENERAL ARRANGEMENT D79-123077 ASSY OF 20 UNITS EA. UNITS INST. 20

BASIC MACHINE ASSEMBLY D79-100069-G4

WITH VALVES YES

WITHOUT VALVES _____

INCLUDING GAGE PANEL YES

HEADER SIZES:

FEED 8"

DISCHARGE 8"

REJECTS 6"

HEADER AND TROUGH MATERIAL 316L S/S

FLANGE: VAN STONE

FLANGE: VAN STONE

FLANGE: WELDED

APPLICATION

LOCATION IN SYSTEM First Primary

PRODUCT _____

STOCK _____

FEED FROM System

REJECTS TO Secondary

ACCEPTS TO Second Primary

TYPE OF CONTAMINANT(S) Light Heavies

TEMP _____

FEED (PSI) 35

ACCEPTS (PSI) 5

T/D / % CONS / USGPM
58.08 / .697 / 1384

FLOW: 5.8 / 1.48 / 58

FLOW: 52.2 / .654 / 1326

PUMP

PUMP BY CUSTOMER

MAKE _____

HP _____

IMPELLER _____

MODEL _____

FEET OF HEAD Pump to be sized for 35 PSI @ Header

REMARKS:

w/Ceramic insert 0.65" Dia.

MANUAL M79-008

L/A 79-LA0359-G1

* ALWAYS SPECIFY UNIT SERIAL NO. WHEN ORDERING REPLACEMENT PARTS.